



# AGA CERTIFIED PRODUCT

Certificate Holder: **KARL DUNGS GMBH & CO. KG**

ABN/ACN No. (if applicable): N/A

Manufacturer: **Karl Dungs GmbH & Co. KG**

Agent (if applicable): **Techrite Controls Australia Pty Ltd**

Type of Component: **Combination Control**

Model No. & Description: **DUNGS  
GasMultiBloc  
Combined Regulator and Safety Shut-off  
Valves – Class 1**  
*(Refer [www.aga.asn.au](http://www.aga.asn.au) for more details)*

## **MB-D and MB-DLE Series B01 and B07 Versions**

### **Single Stage Function**

**403 (DN 10) – 20 kPa**

**405 (DN 15), 407 (DN 20), 410 (DN 25), 412 (DN 32), 415 (DN 40) & 420 (DN 50) - 36 kPa**

## **MB-ZRD and MB-ZRDLE Series B01 and B07 Versions**

### **Two Stage Function**

**405 (DN 15), 407 (DN 20), 410 (DN 25), 412 (DN 32), 415 (DN 40) & 420 (DN 50) – 36 kPa**

Relevant Standard(s): **AS 4624 – 2005  
(Incorporating Amendment 1)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

### **This Certificate is issued on the express conditions that:**

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



**Client Manager**

**Certificate Authorised**

Certificate first issued: **23 May 1986**

Certificate No: **4066**

This copy valid from: **6 May 2020**

Refer specification issue: **06**