



# Type Examination Certificate

No. C5AUK 022629 0043 Rev. 00

**Holder of Certificate:** **Karl Dungs GmbH & Co. KG**  
Karl-Dungs-Platz 1  
73660 Urbach  
GERMANY

**Product:** **Fittings (Gas)**  
**Multifunctional control**  
  
**DMV 50050**

The Approved Body of TUV SUD BAPT Unlimited confirms according to the Gas Appliances (Enforcement) and Miscellaneous Amendment Regulations, UKSI 2018:389 (as amended by UKSI 2019:696), that in the conformity assessment procedure in accordance with Article 14 the listed product has been assessed in a type examination (module B - production type) and complies with the relevant provisions according to Annex I on appliances burning gaseous fuels. It refers only to the sample submitted for testing and certification and on its technical documentation. See also notes overleaf.

**Test report no.:** V-M 1676-00/22

**Valid until:** 2032-05-24

**Date,** 2022-05-25

( Johannes Steiglechner )



# Type Examination Certificate

No. C5AUK 022629 0043 Rev. 00

**Model(s):** **DMV 50050**

## Technical data / range of application

gas family	all gases of 1 <sup>st</sup> , 2 <sup>nd</sup> and 3 <sup>rd</sup> gas family
nominal width	DN 50
valve class according to DIN EN 161	A
group according to DIN EN 13611	2
max. operating pressure	5 bar / 500 kPa
ambient temperature	-15°C to +60°C
installation position	actuator in vertical to horizontal position

## Electrical data

nominal voltages	DC 24 V; AC 230 V; 50 Hz
nominal power (start / hold)	2 x 80 W / 2 x 15 W
degree of protection	IP 54

**Tested according to:** **DIN EN 126:2012**  
**DIN EN 161:2013**  
**DIN EN 13611:2011**