



AGA CERTIFIED PRODUCT

Certificate Holder: **KARL DUNGS GMBH & CO. KG**
ABN/ACN No. (if applicable): N/A
Agent (if applicable): **Techrite Controls Australia Pty Ltd**
Type of Component: **Adjustable Pressure Regulators**

JAS-ANZ



www.jas-anz.org/register

Model No. & Description:
(Refer www.aga.asn.au for more details)

Dungs

FRS 503 (Rp 3/8")	FRI 503 (Rp 3/8")
FRS 505 (Rp 1/2")	FRI 505 (Rp 1/2")
FRS 507 (Rp 3/4")	FRI 507 (Rp 3/4")
FRS 510 (Rp 1")	FRI 510 (Rp 1")
FRS 515 (Rp 1 1/2")	FRI 515 (Rp 1 1/2")
FRS 520 (Rp 2")	FRI 520 (Rp 2")
FRS 525 (Rp 2 1/2")	
FRS 5040 (DN40)	
FRS 5050 (DN50)	
FRS 5065 (DN65)	
FRS 5080 (DN80)	
FRS 5100 (DN100)	
FRS 5125 (DN125)	
FRS 5150 (DN150)	

Sizes 8 – 50mm

Temperature: -15°C to 70°C

Class 2, Grade 20

Maximum Rated Working Pressure: 50 kPa

Relevant Standard(s): **AS 4618 – 2019**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- This Certificate remains the property of the AGA; and
- The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.




Client Manager


Certificate Authorised

Certificate first issued: **22 January 2016**

Certificate No: **8241**

This copy valid from: **27 June 2024**

Refer specification issue: **03**

QF714/12