



Type Examination Certificate

No. C5AUK 022629 0048 Rev. 00

Holder of Certificate: **Karl Dungs GmbH & Co. KG**
Karl-Dungs-Platz 1
73660 Urbach
GERMANY

Product: **Fittings (Gas)**
Safety relief valve

FRSBV 1010

The Approved Body of TUV SUD BAPT Unlimited confirms according to the Gas Appliances (Enforcement) and Miscellaneous Amendment Regulations, UKSI 2018:389 (as amended by UKSI 2019:696), that in the conformity assessment procedure in accordance with Article 14 the listed product has been assessed in a type examination (module B - production type) and complies with the relevant provisions according to Annex I on appliances burning gaseous fuels. It refers only to the sample submitted for testing and certification and on its technical documentation. See also notes overleaf.

Test report no.: V 1685-00/22

Valid until: 2032-05-30

Date, 2022-05-31

(Johannes Steiglechner)



Type Examination Certificate

No. C5AUK 022629 0048 Rev. 00

Model(s): FRSBV 1010

Technical data / range of application

gas family	all gases of 1 st , 2 nd and 3 rd gas family
response pressure group according to DIN 33821	AG 5
accuracy class according to DIN 33821	AC 20
lock-up pressure group according to DIN 33821	SG 20
max. operating pressure	1000 mbar / 100 kPa
setting pressure ranges	70 to 350 mbar / 7 to 35 kPa 300 to 830 mbar / 30 to 82 kPa
nominal size, connection	DN 25, Rp 1
ambient temperature	-15°C to +60°C
installation position	spring dome in vertical to horizontal position
electrical data	—

**Tested according to: DIN 33821:2009
DIN EN 13611:2011**