



AGA CERTIFIED PRODUCT

Certificate Holder: **UNI-GERÄTE E. MANGELMANN ELEKTROTECHNISCHE FABRIK GMBH**

ABN/ACN No. (if applicable): **N/A**

Manufacturer: **UNI-Geräte E. Mangelmann Elektrotechnische Fabrik GmbH**

Agent (if applicable): **N/A**

Type of Component: **Vent Valve**

Model No. & Description: **UNI-GERÄTE EVO & EVSO Series**
(Refer www.aga.asn.au for more details)

THREAD DESIGN:

02 -EVO *-4R	NOTE: *=3, 5, 7	MWP 20 kPa
1- EVO *-4R	NOTE: *= 2, 3, 5, 7, 10	MWP 100 kPa
4- EVO *-4R	NOTE: *= 2, 3, 5, 7	MWP 400 kPa
6- EVO *-4R	NOTE: *= 3, 5	MWP 600 kPa
10- EVO *-4R	NOTE: *= 10	MWP 1000 kPa
25- EVSO *-4R	NOTE: *= 5	MWP 2500 kPa
40- EVSO *-4R	NOTE: *= 5	MWP 4000 kPa

FLANGE DESIGN:

1-EVO*N-4R	NOTE: *=5, 7, 10, 12, 15, 20	MWP 100 kPa
1-EVO*N(H)-4R	NOTE: *=5, 7, 10, 12, 15, 20	MWP 100 kPa

Temperature Rating –20 to +60°C (all models)

Relevant Standard(s): **AS 4629-2005 (Inc. Amendment 1 & 2)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.




John Vanderzoo

Client Manager



Certificate Authorised

Certificate first issued: **14 June 2002**

Certificate No: **6204**

This copy valid from: **21 December 2020**

Refer specification issue: **08**